



SELOC Perimeter Fence Site Show, Byram, MS

RFx 3160007081- February 4, 2025, 1:00 pm

Contractor Questions and Answers

	Vendor/Contractor Question	Answer
1.	Are all three gates going to be slide gates?	Yes Sir, and they will be cantilever (referencing 3 main gates), plus a 3 ft personnel gate at the flagpole.
2.	Is this (the west gate) the primary gate?	Yes sir, the west gate (next to Duro-Last)** will be the primary gate for staff entrance and exit.
3.	Is the marked area where the fence will be, and will it join the existing fence (on the Duro-last side)?	Yes, Fence is going to meet but will not tie into the Duro-last fence.**
4.	One contractor suggested to put safety edges on the back rather than have a photo eye to alleviate some maintenance needs down the road.	Ultimately the means & methods used to provide the specified items on the IFB are up to each contractor.
5.	Are these gates going to be in and out?	Yes, the west (next to Duro-Last)** will be in and out, however, the middle gate will be manual with a locking mechanism. The west and east will be free exits with access control applied. East gate will be exit only.
6.	Is there a timeframe for notice to proceed once it is awarded?	Feb 25 the bids will be open, it is in the solicitation for the IFB. The contract would probably be awarded in April (clarified it could be mid-April to mid-May). There has not been any mentioning of a timeframe to complete the project. Sallie said if the vendor wanted to present their own timeline in the bid, feel free to do so. She mentioned a draft of the contract at the back of the packet, you can have your boss/owner or attorneys look at it in advance. John Cox noted

		That once the contract is awarded a meeting would take place to discuss specifics of the project (timeframe, laydown areas, etc.)
7.	Is the money coming out of this year's budget?	We don't look at that at this level, that is determined at another level. We just oversee the bid process and the work. Other sections oversee the money. Normally, payments are processed within 45 days of completion of the work.
8.	Are you supplying power?	Yes. We will provide power to the locations you the vendor specify it will be needed following contract award and prior to construction start.
9.	Is ACG providing the pedestal?	Yes
10.	Do you want us to provide the conduit?	No, we will already have it. Identified there is already conduit run for the west gate (Duro-Last side)** and we would provide and run any additional conduit needed.

** Please refer to the solicitation for RFx 3160007081 to the photo located on page 19 for the fence that is in association with Duro-Last.

Receipt of Acknowledgement of Amendment

Company Name _____

By _____

Printed Name _____

Title _____